

ATMP 50%

Certificate of Analysis

Manufacturing Date	Expiry date	Batch No
2022/05/06	2024/05/05	2022050654

Technical Properties		
Item	Index	Result
Appearance	Yellowish transparent liquid	
Active Content (As ATMP%)	50 min	50.17
Phosphorous Acid (as PO ₃) ₃ -%	3.0 max	1.85
Phosphoric Acid (as PO ₄) ₃ -%	0.8 max	0.48
Chloride (as Cl ⁻)	2.0 max	1.20
PH (1% water solution)	2.0 max	1.86
Density (20°C) g/cm ³	1.30 min	1.33
Fe (as Fe ²⁺) mg/L	10.0 max	3.50
Ca Sequestrant value (mgCoCO ₃ /g)	400 min	430
Conclusion	CONFORMED	

Tester: 

