

## ATMP 50%

## Certificate of Analysis

<b>Manufacturing Date</b>	<b>Expiry date</b>	<b>Batch No</b>
2022/05/06	2024/05/05	2022050654

Technical Properties		
Item	INDEX	RESULT
<b>Appearance</b>	YELLOWISH TRANSPARENT LIQUID	
ACTIVECONTENT(asATMP)%	50 MIN	50.17
Phosphorous acid (as $\text{PO}_3^{3-}$ )%	3.0 MAX	1.85
PHOSPHORIC ACID(as $\text{PO}_4^{3-}$ )%	0.8MAX	0.48
CHLORIDE(as $\text{CL}^-$ )	2.0 MAX	1.20
PH(1%water solution)	2.0 MAX	1.86
DENSITY(20°C )g/cm <sup>3</sup>	1.30MIN	1.33
Fe (as $\text{Fe}^{2+}$ ) mg/L	10.0 MAX	3.50
CA SEQUESTANT VALUE (mgCoCO <sub>3</sub> /g)	400 MIN	430
CONCLUSION	CONFORMED	



Tester:

